Government of Andhra Pradesh

A.P. State Disaster Response and Fire Services Department

No Objection Certificate for Occupancy

To The District Educational Officer. Eluru, Eluru District

File No: 19286/ELR/DFO/2023

Date: 20/07/2023

Sub: Andhra Pradesh State Disaster Response and Fire Services Department - No Objection Certificate for Occupancy to the existing / newly constructed Multi Storeyed Building (The Bodhi Tree

School) M.Selyusha, D.No.7-2-7, Jangareddygudem - Regarding.

Sir/Madam.

- 1. Online Application Dt. 11-07-2023, M.Selyusha, D.No.7-2-7, Jangareddygudem
- 2. Online Inspection Report submitted by Officers of this Department on 20-07-2023.

It is to inform that M.Selyusha applied for No Objection Certificate on 11-07-2023 for Occupancy to the existing / newly constructed Multi Storeyed Building for The Bodhi Tree School at D.No.7-2-7, Jangareddygudem. The officers of the department have scrutinized the information, documents and plans submitted by the applicant along with the undertaking provided by the applicant, and have submitted the following report.

The Bodhi Tree School

- 2. The builder has constructed a Non Multi Storeyed Building with Ground Floor + 2 Upper Floors with a height of 6 Mtrs for Educational Occupancy (Category - B1) in a total plot area of 230.70 sq. meters.
- 3. The builder has provided open spaces all around the building

| Side | Open Space Required as per 119 APBR 2016 | Open Space Provided by the Builder |
|-------|--|------------------------------------|
| North | 1 Meters | 0.10 Meters |
| East | 2 Meters | 0.50 Meters |
| South | 1 Meters | 0.20 Meters |
| West | 1 Meters | 0.05 Meters |

4. The builder has constructed following means of escape:

| SI | Details of Staircases | Required Nos / Meters as per A.P.B.R | Required based on Floor Area | Provided Nos / Meters |
|----|-----------------------|--------------------------------------|---------------------------------|--------------------------|
| 1 | Internal Staircases | Min 1 No Meters | | 1 No 1.00 Meters |
| 2 | External Staircases | Min I No Meters | <u> </u> | 0 No 0.00 Meters |
| | Total | 1 Nos. | 0.00 Meters | 1 Meters |

5. The builder has proposed to provide Occupant Load:

| SI | Floor | Built up area (Sq Mtrs) | Occupancy Type | No of Occupants as declared by the builder | No of Occupants as per NBC | Aggregate width of Staircases Required (Meters) | Aggregate width of Staircases Provided(Meters) |
|----|-----------------|-------------------------------|-------------------|--|----------------------------------|---|--|
| 1 | Ground Floor | 161.73 | Educational | 35 | 40 | 0.35 | 1.00 |
| 2 | First Floor | 161.73 | Educational | 35 | 40 | 0.35 | 1.00 |

| SI | Floor | Built up area (Sq Mtrs) | Occupancy Type | | No of Occupants as per NBC | Aggregate width of Staircases Required (Meters) | Aggregate width of Staircases Provided(Meters) |
|----|--------------|-------------------------------|-------------------|-----|----------------------------------|---|--|
| 3 | Second Floor | 161.73 | Educational | 35 | 40 | 0.35 | 1.00 |
| | Total | 485.19 | - | 105 | 120 | | |

6. The minimum Fire Fighting Installations required and provided as per Table 7 of Part 4 of National Building Code of India 2016 are:

| el . | Fire Safety System | Minimum Required | Provided |
|------|---------------------------------|------------------|----------|
| 1 | Fire Extinguishers | 6 Nos. | 0 Nos. |
| 1 | Hose Reel Systems | 3 Nos. | 0 Nos. |
| 3 | Terrace Tank | 10000 Ltrs | Ltrs |
| 1 | Booster Pump | 450 LPM | |
| 5 | Additional Fire Safety measures | NA | |

7. The builder has provided the following floorwise Fire Fighting installations as per Table 7 of Part - 4 of NBC of

| SI. | 2016. Floor | FireHose Wet Down Yard Ext, Reel Riser Comer Hydrant | Sprinklers | MCP | Auto.U Det. | nderground Tank | Terrace Tank | Fire Pump | Booster Pump | Addi |
|-----|----------------|---|------------|------|----------------|--------------------|------------------|-----------|-----------------|------|
| 1 | | 2/-1/- | 0 / | 0 / | 0 / | | | | | |
| 2 | | 2/-1/- | 0/ | 0 / | 0 /- | | | | | |
| 3 | Second | 21-11- | 0/ | 0 / | 0/- | | | | | |
| 1 | Total | 6/0:3/0 -///- | 0 /0 | 0 /0 | 0 /0 | -/ | 10000 Ltrs /- | - / | 450 LPM / | / |

· Provide ABC 5 kg/6 kg fire extinguishers

8. The Officers of the department have recommended to issue The No Objection Certificate for Occupancy of Non MSB Educational Building (B1) belonging to M.Selyusha D.No.7-2-7, Jangareddygudem, subject to the following conditions.

The No Objection Certificate for Occupancy is issued subject to the following conditions:

- 1. This NOC is issued only in the Fire Safety Point of View and this doesnot give the Applicant a right to claim ownership of the property.
- 2. All fire safety systems provided shall be maintained in trim working condition at all times.
- 3. All Security/ Maintenance personnel shall be trained on the usage of fire equipment provided.
- 4. Fire Drills shall be conducted once in every 3 months.

5. As per report of Non MSB Inspection committee; the NOC Committee has scrutinized the Inspection Committee Report along with Proposals and recommended for issuance of No Objection Certificate for Occupancy subject to the following Conditions.

| SI | As Builder | As Occupant | As Security Personnel |
|----|---|-------------------------------|--|
| | All the fire protection arrangements shall be maintained in good condition as seen during inspection. | not be kept locked/blocked or | All the occupants must know the correct method of operation of the fire fighting system installed. |

| | | AND RESIDENCE AND ADDRESS OF THE PARTY OF TH |
|---|--|--|
| Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibilty of the management. | All occupants shall be trained to operate the fire safety equipments during emergency. | Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months. |
| Addition / alteration, if any in the building may be verified by building authority. | Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months. | All security personnel shall be trained to operate the fire safety equipments during emergency. |
| This No objection Certificate for | Raise the alarm if the fire cannot | Attack the fire using available fire equipment only if you feel |
| occupancy is valid for one year | completely at once from nearest | capable of controlling. If not, take all steps to isolate the area by closing doors and windows. |
| | non-functioning of fire safety measures and other installations shall be the responsibilty of the management. Addition / alteration, if any in the building may be verified by building authority. This No objection Certificate for occupancy is valid for one year | non-functioning of fire safety measures and other installations shall be the responsibilty of the management. Addition / alteration, if any in the building may be verified by building authority. This No objection Certificate for occupancy is valid for one year completely at once from nearest completely at once from nearest |

6. This No Objection Certificate for Occupancy is valid for a period of one year only from the date of issue of this letter. It is the responsibility of the builder to apply for Renewal of No Objection Certificate for Occupancy, duly remitting the User Charges as per G.O.Ms.No.71, Home (Prison-A) Department, dated 01-04-2010 and G.O.Ms.No.140, Home (Prison & Fire) Department, dated 04-09-2015, before expiry of this No Objection Certificate.

9. The following deficiencies are identified by the officers of the department and need to be attended to by the management.

In view of the above, as per the recommendations of the NOC Committee, the No Objection Certificate for Occupancy is hereby issued to the Newly constructed Non Multi Storcyed Building subject to the above conditions.

Your Sincerely,

District Disaster Response & Fire Offices
Andhra Pradesil Quid

Copy to M.Selyusha, M.Selyusha, The Bodhi Tree School, D.No.7-2-7, Jangareddygudem, Eluru District Copy to Assistant District Fire Officer concerned Copy to Station Fire Officer concerned